Attention : LOU Procurement

Date:
19 August 2026

Enquiries:
Tel +27 11 709 3769

Dear Tenderers

ADDENDUM TO TECHNICAL EVALUATION CRITERIA

TECHNICAL EVALUATION CRITERIA FOR POLE AND GROUND MOUNTED TRANSFORMERS - Unique Identifier: 240-128700801.

Please take note of the following changes to the above-mentioned Technical Evaluation Criteria:

1. Section 12: Electronic Submissions

Section 12 states that: *"Electronic submissions containing all the required technical evidence stated in this document are to be included in the tender submission. This electronic submission is in addition to the hard copy printed submissions and will not be valid if the original printed documentation is not supplied as per the requirements of the commercial enquiry.*
Electronic submissions must contain PDF'ed information that is searchable for ease of reference.":

This section should read as follows: "Electronic submissions containing all the required technical evidence stated in this document are to be included in the tender submission. Electronic submissions must contain PDF'ed information that is searchable for ease of reference."

2. Please note that the following technical requirements/information have been added

- Only Ester Oil options will be accepted. Mineral oil-filled units are not accepted
- Bidder Cover Letter Template: The bidder must provide a Bidder Cover Letter for the technical submission indicating for each item on scope:
    a) Was the item on the previous Eskom contract?
    b) Has a design review been conducted?
    c) Have there been changes since the last design review?
    d) Has the factory been accredited by Eskom?
    e) Have there been changes to the factory since the last accreditation?
- The Bidder Cover Letter must be submitted with the bid and may be requested if not included.

Procurement and Supply Chain Management
Sourcing Wires
90 Hans Van Rensburg Street
Private Bag X9477, Polokwane 0699 SA
Tel +27 15 230 1729 Fax +27 86 661 1062 www.eskom.co.za
Eskom Holdings SOC Ltd Reg No 2002/015527/30

- OEMs offering transformers from Eskom unaccredited factories must be fully Eskom accredited prior to contract award.
- OEMs offering transformers without an Eskom approved design review are required to have design reviews conducted by an Eskom qualified/trained team.

3. Scoring Methodology

The scoring methodology below applies to TEC 240-128700801.

Score	%	Definition
5	100	**COMPLIANT** • Meet technical requirement(s) AND; • No foreseen technical risk(s) in meeting technical requirements.
4	80	**COMPLIANT WITH ASSOCIATED QUALIFICATIONS** Meet technical requirement(s) with; • Acceptable technical risk(s) AND/OR; • Acceptable exceptions AND/OR; • Acceptable conditions.
2	40	**NON-COMPLIANT** • Does not meet technical requirement(s) AND/OR; • Unacceptable technical risk(s) AND/OR; • Unacceptable exceptions AND/OR; • Unacceptable conditions.
0	0	**TOTALLY DEFICIENT OR NON-RESPONSIVE**

Compiled by:

Jabu Mahlangu
Senior Technologist Electric
Limlanga Cluster

Approved by:

Mmedi Motaung
Standard Implementation Manager
Limlanga Cluster